


CIRCOLAZIONE FLUIDI CIRCUITO PRIMARIO C - D (PRIMARY CIRCUIT C - D)  
CIRCUITO SECONDARIO A - B (SECONDARY SANITARY CIRCUIT A - B)



CODICE / CODE	N° PIASTRE / N° OF PLATES	H (mm)
17B5001004	10	32
17B5001404	14	41
17B5002004	20	54
17B5002404	24	63
17B5003000	30	77
17B5004004	40	99
17B5005004	50	122
17B5006004	60	144
17B5008004	80	189

P max,  
 Massima pressione d' esercizio / Max operating pressure: 30 bar  
 Temperatura esercizio / Max operating temperature: -50/+200°C  
 Materiale / Material: ACCIAIO INOX AISI 316L  
 Materiale di brasatura / Brazing material: 99.9% Cu

 <small>35010 Limena (PD) Via del Santo 242 tel.049/7664901</small>	DRAWING N° <b>ZB 500</b>			<b>CODICE / CODE</b> <b>17B500--04</b>								
	Denominazione / Denomination <b>SCAMBIATORE DI CALORE SALDOBRASATO / BRAZED HEAT EXCHANGER</b>	<table border="1"> <tr> <td>Drawn</td> <td>Date</td> <td>Signature</td> </tr> <tr> <td>Checked</td> <td>Date</td> <td>Signature</td> </tr> <tr> <td>Approved</td> <td>Date</td> <td>Signature</td> </tr> </table>	Drawn		Date	Signature	Checked	Date	Signature	Approved	Date	Signature
Drawn	Date	Signature										
Checked	Date	Signature										
Approved	Date	Signature										